

For Expert comments on Issue #1 – [click here](#)

Summary of case study is as follows.

Annual Coal saving :- 22457.29 T
Annual Rs. saving :- 4.04 Rs. Crore
Simple Pay Back :- 0.99 ~ 1 Year

Please consider my solution for publishing if found correct.

Thanks & Regards,
EA-4760, Santosh M. Mestry
Reliance Energy, Dahanu Thermal Power Station
RIM - 9325119771
Landline - 02528 225001 EXT -701

For Expert comments on Issue #1 – [click here](#)

ISSUE#1: JUNE 2008 IGEN-THERMAL POWER PLANT CORNER				
ESTIMATION OF SAVING DUE TO CONTROL OF DESUPERHEATER WATER SPRAY				
	STEP	PARAMETER	UNIT	VALUE
GIVEN INFORMATION	A	PLANT CAPACITY	MW	140
	B	CURRENT GENERATION	MW	110
	C	OPERATING MS PR.	KGS	120
	D	MS FLOW	TPH	390
	E	OPERATING MS TEMP.	0C	536
	F	MS ENTHALPY	KCAL/KG	822.9
	G	DESUPERHEATER SPRAY	TPH	30
	H	DESUPERHEATER SPRAY PR.	KGS	128
	I	DESUPERHEATER SPRAY TEMP	0C	170
	J	DESUPERHEATER SPRAY ENTHALPY	KCAL/KG	173.4
	K	MS TO MW RATIO AT OPERATING CONDITION	TPH/MW	3.5
	L	SP.COAL CONSUMPTION	KG/KWH	0.65
	M	COAL GCV	KCAL/KG	4600
	N	LANDED COAL COST	RS/TON	1800
	O	STEAM CONSUMPTION IN SOOT BLOWER	T/DAY	110
	P	SELLING PRICE PER KWH	RS/KWH	2
	Q	SOOT BLOWER REPAIRING COST	RS CRORE	4
	U	BOILER EFFICIENCY	%	80
	S	ANNUAL PLANT OPERATING HRS	HR	7000
	T	REDUCTION IN SPRAY AFTER CORRECTING SOOT BLOWER	TPH	7
CALCULATION	$V=(D(F-J)+G(F-J))/(B*U)$	** EXISTING PLANT HEAT RATE	KCAL/KWH	3099.89
	$W=(D(F-J)+T(F-J))/(B*U)$	NEW HEAT RATE AFTER IMPLEMENTING PROPOSAL	KCAL/KWH	2930.13
	$X=V-W$	REDUCTION IN HEAT RATE	KCAL/KWH	169.76
	$Y=(X*B*S)/M$	ANNUAL COAL SAVING DUE TO IMPROVED HR	T/YEAR	28415.63
	$Z=Y*N$	SAVING OF COAL CONSUMPTION IN RS	RS/ANUM	51148125.00
	$AA=P*(L*N/1000)$	OPERATING PROFIT CONSIDERING COAL COST	RS/KWH	0.83
	$AB=(O/K)*(S/24)$	LOSS OF GENERATION DUE TO SOOT BLOWING STEAM CONSUMPTION	MW/ANNUM	9166.67
	$AC=AB*AA$	GENERATION LOSS IN RS DUE TO SOOT BLOWING STEAM CONSUMPTION	RS/ANNUM	7608.33
	$AD=K/L$	EVAPORATION RATIO OF BOILER		5.38
	$AE=(S*(O/AD))/24$	ADDITIONAL COAL REQUIRED FOR SOOT BLOWING STEAM	TON/ANNUM	5958.33
	$AF=AE*N$	ADDITIONAL COAL REQUIRED IN RS FOR SOOT BLOWING STEAM	RS/TON	10725000.00
	$AG=Y-AE$	NET COAL SAVING	TON/ANNUM	22457.29
	$AH=(Z-AC-AF)/10000000$	NET RS. SAVING	RS.CRORE/ANNUM	4.04
$AI=Q/AH$	SIMPLE PAYBACK PERIOD	YEAR	0.99	
**	FEEDWATER ENTHALPY IS TAKEN SAME AS DESUPERHEATER SPRAY ENTHALPY			