



FLOW DIAGRAM OF Paper Machine



LOSS IDENTIFICATION COMMITTEE

- HIGHLIGHT PROCESS INEFFICIENCIES
- CHECK LOSSES OF ALKALI, FIBRE, WATER, CHEMICAL AND STEAM
- ARRANGE CORRECTIVE MEASURES

ANNUAL SAVING IN POWER UTILISATION WITHOUT INVESTMENT

ONLY MENTAL ENERGY

S.NO.	SCHEMES	INVESTMENTS (Rs IN LACS)	SAVINGS (Rs IN LACS)
1.	REDUCED TG FREQUENCY	0	76.20
2.	OPTIMISE TG VOLTAGE	0	3.62
3.	OPTIMISE RGP VOLTAGE	0	2.49
4.	PUT OFF 12.5 MVA TR SET	0	3.02
TOTAL		0	85.43

EC MEASURES IN ELECTRICAL

- PROVISION OF LOAD TRANSFER FROM GRID TO TG WITHOUT INTERRUPTION TO UTILIZE SOURCES
- PREVENT IDLE RUNNING OF EQUIPMENTS BY
 - ✓ INTERLOCKING OF PUMPS & AGITATORS
 - ✓ EFFECTIVE CONTROLS LIKE ONE PB FOR A GROUP OF EQUIPMENTS
 - ✓ SWITCH OFF EQUIPMENTS THROUGH TIMERS
- INSTALLATION OF VFD FOR VARIABLE FLOW / THROTTLED VALVES
- DELTA - STAR FOR LIGHTLY LOADED MOTORS
- NEUTRAL COMPENSATORS FOR UNBALANCE LOADS
- LED'S FOR INDICATING LIGHTS
- LOW LOSS HRC FUSES
- USE OF ENERGY SAVERS FOR LIGHTING CIRCUITS
- USE OF PHOTO CELLS FOR STREET LIGHTS
- SPLITTING OF CIRCUITS FOR BETTER CONTROL

ELECTRICAL ENERGY SAVINGS

	2004-05	2005-06	2006-07	2007-08
NO OF SCHEMES	34	111	75	71
SAVINGS / ANNUM				
KWH (LACS)	37.29	84.26	29.23	79.89
Rs (LACS)	76.58	175.15	59.08	159.68
INVESTMENT	84.20	94.30	42.21	374.0
COST OF ELECTRICITY				
Rs 2.10				

Rs 393.9 lacs

ENERGY CONSERVATION MEASURES IN THERMAL

- EFFICIENT MEANS OF HEATING
- EFFICIENT HEAT TRANSFER
- OPTIMIZATION OF BOILERS FOR COMBUSTION, FLUE GAS TEMPERATURE, EXCESS AIR
- INCREASED UTILISATION OF PITH
- MINIMIZE THERMAL LOSSES & WASTAGES
- THRUST ON WASTE HEAT RECOVERY

ENERGY CONSERVATION MEASURES IN PROCESS

- CAPACITY MATCHING WITH THE REQUIREMENT
- PREVENT IDLE RUNNING OF EQUIPMENT
- USE OF CONTINUOUS PROCESS INSTEAD OF BATCH PROCESS
- UPGRADATION OF TECHNOLOGY
- USE OF HIGHER EFFICIENCY EQUIPMENT
- THRUST ON WASTE HEAT RECOVERY

THERMAL ENERGY SAVINGS

	2004-05	2005-06	2006-07	2007-08
NO OF SCHEMES	12	14	10	5
SAVINGS PER ANNUM				
EQ COAL (Eq)	20438	57891	27106	27681
Rs LACS	387.8	1235.7	505.05	512.1
INVESTMENT	444.47	2981.7	1159.1	277.82
COST OF COAL	Rs 1850/TON			

Rs 2253 lacs

TOTAL ENERGY SAVINGS FOR LAST 3 YEARS

	2004-05	2005-06	2006-07	2007-08
INVESTMENT (LACS)	528.9	3076.0	1201.3	1025.84
KWH (LACS)	37.29	84.26	29.23	79.89
COAL EQ. (TONS)	20438	57891	27106	27681
Rs LACS	464.4	1410.8	564.1	671.8
Rs. 5303 lacs	Cumulative Savings			Rs2647 lacs




COMPARISON WITH NATIONAL STANDARDS






ENERGY (POWER & STEAM) CONSUMPTION NORMS (as recommended by CPPRI under EC ACT 2001)


WITH IN BATTERY LIMITS			
ELECTRICAL	kwh/T	1197.71	
STEAM	T/T	9.15	
OUTSIDE BATTERY LIMITS			
ELECTRICAL	kwh/T	124.64	
STEAM	T/T	1.20	
TOTAL			
ELECTRICAL	kwh/T	1323.35	
STEAM	T/T	10.35	

1213 Kwh/t
6.93 T/t

- ### INNOVATIVE SCHEMES
- ❖ Optimization of soft wood refiner operations
 - ❖ Deflaker chest level interlock
 - ❖ DOCC filter
 - ❖ Utilization of biomass waste
 - ❖ Repl. of worm & gear arrangement by geared motors








❖ REPLACEMENT OF WORM & GEAR ARRANGEMENT BY GEARED MOTORS FOR 42 NOS SURFACE AERATORS

SURFACE AERATORS WERE DRIVEN BY 15 Kw MOTORS ALONGWITH REDUCTION GEAR BOXES. REDUCTION WAS THROUGH WORM & PINION ARRANGEMENT WHICH HAD LOW EFFICIENCY.

These were replaced by GEARED MOTORS resulting in a savings of 2.96 kw each due to high efficiency.

Investment	Rs	70.00 lacs
Annual savings	Rs	21.77 lacs



WATER CONSERVATION ACHIEVED THROUGH 8 MAJOR SCHEMES IMPLEMENTED IN LAST THREE YEARS

- Recycling of bleaching back water
- Recycling of sheeting M/c. back water
- Recirculation of lime kiln cooling water
- Reclamation of paper M/c. & stock back water