

WEL-COME
TO

ENERGY MANAGEMENT SYSTEM



**PRESENTED BY
M.L.PATIDAR
MARK ENGINEERING
SERVICES
BHILWARA
09413356581**



Area of Presentations

- A) Spinning
- B) Weaving
- C) General



Subjects:

1. Compressed Air System
2. Humidification System
3. Distribution System
4. Project Planning
5. DSM



Compressed Air System

Case Study-1

Modification of Compressed Air System-Spg Un it

S.N,	Pre-Condition			New Conditions		
A	Compressors					
	CFM	Nos	TTL CFM	CFM	Nos	TTL CFM
i)	155	7	1085	576	2	1152
ii)	120	1	120	460	1	460
iii)	460	1	460			0
			1665			1612
B	Pressure	8.5-9	Bar		6.8-7.1	Bar
C	Pressure Drop	0.7-1	Bar		0.3	Bar
D	Load HRs	100	%		85	%
E	Energy Cosn	8200	KWH		6000	KWH
G	Annual Saving				3465000	INR
H	Capex				1750000	INR
I	ROI				6	Mths



■ Steps & Observations:

- 1. Replaced compressor by hi-eff machines
- 2. Modified Air Pipe lines and reduced Pressure drop.
- 3. Machines wise air consumption analysis and arrested leakages
- 4. Optimize the pressure
- 5. Daily monitoring of loading hrs and energy consumption

Case Study-2

Regulated Pressure Control

S.N.	Particulars	Specs	Unit
	Compressor Rating	806	CFM
	Type of Machine	Sphiral Valve regulated	
	Actual Air requirment	650	CFM
	Prev Energy Consumption	3700	KWH/Day
	Revised Energy Consn	3200	KWH/Day
	Annual Saving	175000	KWH
	Unit Rate	3.4	INR
	Saving	595000	INR
	Repairing Cost	30000	INR
	Pay Back	Immediate	





- Observations:

- 1. Auto regulating (Spiral) Valve defective.

- 2. Pressure became constant instead of 1 bar variation

Air Leakage Monitoring of Machine

S.N.	DATE	UNIT	MACHINE	AIR CONSUMPTION BEFORE MAINT(CFM)			AIR CONSUMPTION AFTER MAINT(CFM)		
				M/C IDLE	STARING	RUNNING	M/C IDLE	STARING	RUNNING
1	13.05.05	A	A/C-4	72	105	103		NOT ATTENDED	
2	14.05.05	C	A/C-4	22.5			5	17.5	
3	14.05.05	C	A/C-5	26			5	21	
4	14.05.05	C	A/C-6	47			5	42	
5	14.05.05	C	A/C-7	14			5	9	
6				5				89.5	
7	4.07.05	A	A/C-01	64	145	72	5	59	
8		A	A/C-03	44	65	35	5	39	
9		A	A/C-04	12	59	20	5	7	
10		A	A/C-05	17	90	20	5	12	
11		A	A/C-06	37.5	118	35	5	32.5	
				361					

- 
- 
- Observations:
 - There was leakage of Air 4 Times of Normal requirement.
 - Repairing/Replacement cost of defective part for on machine was Rs2500/ only
 - Annual Loss of Rs 3.50Lac in one machine.
 - By regular checks it can be avoided



■ **General Recommendations for compressed Air system in Spinning Units**

- Install compressors at clean and free flowing air side
- Design Pipe line considering minimum pressure drop.
- Keep Optimum pressure(As Lower possible)
- Keep Air filter clean regularly
- Install efficient dryer for dry air.
- Use Zero loss drain valves
- Replace rubber kits of Pneumatic equipments periodically
- Arrest leakages
- Use regulators where low pressure is required
- Clean/Replace Line filter regularly to avoid pressure drop

Case Study of Air Jet Looms

Particulars	Previous	Post
Installed Looms	96	96
Running Looms	79	79
Installed Compressors(CFM)	4183	4183
Running Compressors(CFM)	3713	2632
Avg. Consumption(CFM)	3160	2370
Pressure(Bar)	6.90-7.50	5.80-6.10
Average Production/day(Mtrs)	20500	20500
Total Energy(KWH)	15100	10600
Energy Cost(Rs/Day)	67950	47700
Saving/Day(Rupees)		20250
Annual Saving(Rupees)		7087500
Investment(Rupees)		50000
Pay Back	Days	2.5

Observations

- **Problems detected.**
- 1. Operating at very high pressure at 6.8-7.5 bar while required 4.5-5.5 bar at machine.
- 2. Leakages in machines up to 50% extra than normal consumption
- 3. Pressure drop up to 1.00 bar, with small changes reduced it to 0.3 bar
- 4. Replaced Defective Nozzles in the machines.

Case Study -2

Compressed Air System in Air Jet Looms-2		
Particulars	Previous	Post
Installed Looms	30	30
Running Looms	26	30
Installed Compressors(CFM)	1040	1040
Running Compressors(CFM)	1040	1040
Avg. Consumption(CFM)	1040	1040
Pressure(Bar)	5.80-6.10	5.80-6.10
Average Production/day(Mtrs)	11180	12900
Total Energy of Compressor(KW)	4638	4368
Energy Cost(Rs/Day)	19656	19656
Energy Cost(RS/Mtr)	1.76	1.52
Annual Saving(Rupees)		1058400
Investment(Rupees)		25000
Pay Back	Days	8.62 Days

Case study (Cont.):

■ Steps Taken

- 1. Reduced Pressure from 7.00 bar to 6.5 Bar
- 2. Arrest leakages
- 3. Setting of Nozzels to control the air
- 4. Replaced continuous operated drain valves to zero loss valves



- **Humidification System**

Case Study Humidification Plant of Spg Unit

Humidification Plant Analysis

Plant	Heat Load	RH%	CFM Required	Measured			CFM/Power
				CFM	Power (KW)	RH%	
Finishing-A	813570	65	81357	71000	46.2	35	1536.797
Finishing-B	649082	65	64908	67800	28.2	46	2404.255
Finishing-C	832517	65	83252	86500	27.88	46	3102.582
R/F-A	940402	50	67172	57720	24.72	35	2334.951
R/F-C	840530	50	60038	36600	26.24	36	1394.817
Prep-C	375052	50	26789	22081	16.52	35	1336.622

Remark: Due to poor maintenance of the plant desired RH is not achieved even power consumed and air flow is normal.

Observations:

1. Air washer plant are not maintained.
2. RH after eliminators are below 70% while it should be above 90%
3. Due to this overall plant operation is at higher side.
4. SA Ducting is damaged

Case Study on Fans selection

FRP/Alluminium Fans

Date 9.08.1998

A	Fan Type	Alluminium			
	S.N.	BKW	CFM	TP	CFM/KW
	1	14.65	86909	23.07	5932.355
	2	18.05	67375	44.47	3732.687
	3	17	55865	44.26	3286.176
	4	16.83	51916	53.25	3084.73
	5	18.54	23821	63.37	1284.844

B	Fan Type	FRP
---	----------	-----

i)

S.N.	BKW	CFM	TP	CFM/KW
1	13.72	92258	11.76	6724.344
2	19.48	71463	45.15	3668.532
3	20.3	54580	53.09	2688.67
4	20.29	49108	56.4	2420.306

Date 14.07.2004

ii)



S.N.	CFM		TP		BKW		CFM/KW	
	FRP	ALU	FRP	ALU	FRP	ALU	FRP	ALU
1	51205	51192	26.98	26.48	11.56	10.8	4429.498	4740
2	40726	41680	45.42	47.84	13.32	13.42	3057.508	3105.812
3	34378	37545	49.16	55.7	13.39	14.04	2567.438	2674.145
4	30716	32284	52.68	61.18	13.25	14.22	2318.189	2270.323
5	29055	31507	55.47	63.58	13.03	14.43	2229.854	2183.437

1
1

Remark :

Whenever fans are replaced need to check its velocity and static and Total pressure to evaluate real performance. Velocity may quite high with same energy but pressure will reduced and

- it will effect the overall system performance.

- 
- 
- During selection of fans, check the efficiency comprising of velocity and Total pressure which is normally 45mmwc. If Pressure is less than standard then air will not pass to the whole area.
 - Fan material is not important rather than its profile and application duty.

Case Study of Supply Air Fans

Optimisation of Humidification Plant

Fan Speed Control

Particulars	Pre-Condition	Post Conditions	
Fan Angle	16	12	
Fan Speed	1450	1450	
No.of Fans	1	2	
Motor HP(Each)	15	15	
Net KW	11	6	
Total Power	11	12	
Velocity(CFM)	32000	47000	
Deptt Temp	31	28	
Deptt RH	60%	65%	
SEC(KW/1000CFM)	0.34	0.26	
Energy Gain		25.73	%

Observations:

- 1 One fan motor was running overloaded
- 1 One Fan was not designed for such high velocity
- 3 Fans air flow and power ration increase at ratio 1:2.7
- 4 No proper commissioning of the plants

.

Case Study on Spot Humidification

Options of Humidification System

S.N.	Particulars	Normal Humidification	SpotHumidification
1	Type of Plant	Air jet Weaving	Air jet Weaving
2	MachineRH Required	78+/-3%	78+/-3%
3	Room RH Reqd	60%	60%
4	Plant Recoomonded(CFM)	130000	80000
5	RA Sytem	Rotary Filter	Rotary Filter
6	BKW at Full Capacity	65	55
7	Total Power(KW)	72	61
8	L.F	70%	70%
9	Average Load(KW)	50	43
10	Average Run Hrs/Day	18	18
11	Annual working days	350	350
12	Annual Energy Consumption(KWH)	315000	270900
13	Capital cost (Rs in Lacs)	25	25
14	Annual Energy Cost(Rupees)	1354500	1164870
15	Annual Saving(Rupees)		189630

Tips On Humidification System

- 1. Design Parameters (Actual LF, Actual RH Required, Design of velocity at all the area like Damper, SA Ducts, Grill, Diffusers, Air washer),
- 2. Operation skill
- 3. Preventive maintenance. (Ensure above 90% RH after Air washer.
- 4. Insulation(Without insulation, building factor increase by 2.5Times)
- 5. Discharge of Pnumafil air out side the plant (During summr & Mansoon)



- DSM

Case Study of Improved Machines Efficiency

SCOPE OF POWER SAVING AGAINST IMPROVED EFFICIENCY								
				Consumption	91000KWH/Day			
M/C	%TTL UNITS	KWH/DAY		ECTIMATED SCOPE OF SAVING				
			EFF.	WASTE	MISUSE	MAINT.	TTL	KWH/DAY
B/ROOM	5	4575	4	0.3	0.1	0.1	4.5	205.875
CDG	5.5	5032.5	5	0.5	0.2	0.2	5.9	296.9175
D/F	1.9	1738.5	2	0	0	0.1	2.1	36.5085
S/F	2.4	2196	4	0.5	0	0.1	4.6	101.016
R/F	24	21960	1.5	0.3	0.25	3	5.05	1108.98
AUTO/WDG	9	8235	9	0.3	0.25	1	10.55	868.7925
TFO	22	20130	3			0.5	3.5	704.55
DBLG	5	4575	2	0.2		0.2	2.4	109.8
							TOTAL	3432.44
In Terms of Rs. 42.00 Lacs Per Annum								

Case Study for optimization of Machine speed(TFO)

Overall Profitability of 8Nos 2x192 drums TFO machines

Overall Calculations for		330 Days/Annum		No. of Machines 8		
				Unit Rate	4.3	
	Options	I	II	III	IV	V
1	Speed	7000	7500	8000	8500	9000
2	Efficiency	85	85	85	85	85
3	Production/Day(Kgs)	412	442	471	500	530
4	Prodn/Annum(Kgs)	1087999	1165713	1243427	1321142	1398856
5	Total Units	861960	957000	1070018	1191066	1452733
6	Ukg	0.79	0.82	0.86	0.90	1.04
7	Enrgy Cost	4525290	5024250	5617597	6253095	7626846
8	Intt.	900000	900000	900000	900000	900000
9	Depriciation	1551000	1551000	1551000	1551000	1551000
10	Maintenance	600000	600000	600000	600000	600000
11	office Expenses	300000	300000	300000	300000	300000
12	Manpower cost	2275000	2275000	2275000	2275000	2275000
13	Packing & Cost	543999	582857	621714	660571	699428
14	Total cost/Annum	10695289	11233107	11865310	12539666	13952274
15	Rs/Kgs	9.83	9.64	9.54	9.49	9.97
16	S.P.	10.00	10.00	10.00	10.00	10.00
17	Profit(Rs/Kgs)	0.17	0.36	0.46	0.51	0.03
18	Total Profit/Annum	184700	424025	568963	671750	36283

DSM Recommendation

- 1. Optimize machine speed compare to energy consumption and overall profitability
- Concentrate on improvement of machine efficiency
- Energy V/S Production comparison
- Optimize the humidity requirement by spot humidification and direct water application wherever possible.
- Maintain machines properly to avoid jammings and air leakages
- Avoid idle running of machines.
- Minimize waste generation.
- Avoid cleaning by compressed air

Training

1. With management (To develop energy conservation cell and budget approvals)
2. For Supervision staff
3. For operators
4. For maintenance team

Involve each and every person of organization to implement the energy saving activities



- **Distribution System**

Case Study of Distribution Losses

Location of Transformers(Line Losses)						
A	Previous Condition					
	Transformer Capacity		1000KVA			
	Voltages (HT/LT)		11000/415			
	Loading		600KVA		Cost	
	HT Cable Size		3Cx50 Sqmm	15Mtrs	6750	
	LT Cable		4Nosx3.5Cx240Sqmm	4x100Mtr	280000	
					286750	
	Actual Current (HT)			31.5 Amps		
	Actual Current (LT)			834 Amps	208	Amps/Cable
	Line Los (HT)		25.4 watt			
	Line Los (LT)		8490watt			
	Total		8515 watt			
	Annual Cost Rupees			306648		
B	By Change of Transformer Location				Cost	
	HT Cable Size		3Cx50 Sqmm	90Mtrs	40500	
	LT Cable		4Nosx3.5Cx240Sqmm	4x25Mtrs	70000	
					110500	
	Line Los (HT)		152.4 watt			
	Line Los (LT)		2115 watt			
	Total		2267.4 watt			
	Annual Cost Rupees			81612		
	Net Savings(In 1St Year)					
	Energy Rupees			225036		
	Capital Rupees			176250		
	Total Rupees			401286		

Case Study on Transformer Loading

TRANSFORMER DETAIL				
	Transformer1	Transformer2		
LOCATION	HT Yard	HT Yard		
SR NO	333869	6611		
MAKE	Crompton	Crompton		
CAPACITY IN KVA	2000	1600		
YR OF MANUFACTURING	1984	1996		
COOLING ARRANGEMENT	ONAN	ONAN		
PRIMARY SIDE HT				
	VOLTAGE	33000	33000	
	AMPERE	35	28	
SECONDARY SIDE LT				
	VOLTAGE	433.3	433.3	
	AMPERE	2666.7	2134	
Vector Group	Dyn-II	Dyn-II		
RATED FREQUENCY	50	50		
RATED TEMP (OIL / WINDING)	45	50		
NO LOAD LOSSES AT RATED VOLTAGE	2.1	1.9		
FULL LOAD LOSSES AT RATED VOLTAGE	22.6	18.9		
IMPEDANCE %	6.49	6.49		
TAPING POSITION	10	10		
TAP CHANGING METHOD	OLTC	OLTC		
Loading(KVA)	1400	0		
Total Losses(KW)	13.174	0	13.174	
Revised Loading	800	600		
	5.72	4.56	10.27	
Net Saving			2.900188	KW
Annual Saving(8000hrs)			23201.5	KWH
		Rupees	104406.8	Per Annum
Investemt			0	
Payback			Immidiata	

• **Best Loading of Transformer=** $\sqrt{\text{Iron Loss}/\text{Copper Loss}} \times \text{Transformer Rating(KVA)}$



- General Practice:

Most of Capacitors installed Near Main Distribution Panel with APFC

Resulting: PF maintained up to unity and PF incentive benefit avail up to the maximum level.

But benefit of internal line losses reduction due to high PF and low current is missing

Recommendation: As possible put capacitors parallel to load at load end.

General Recommendations

- 1. Maintain voltage drop below 1% at load point.
- 2. Optimum loading on transformer considering total load losses
(Tr Loss = NL Loss + SQ(LF) x FL Loss)
- 3. Installed capacitors at load end, only, for fine correction minimum quantity at APFC
- 4. Keep optimum voltage.

Other Area of Saving

- 1. Lighting System
- 2. Pumps
- 3. Machines Maintenance

Project Planning

- A: Compressor:
 1. Select Model according to air requirement i.e.Reci/Rotary/Cetri.
 2. Keep rating of compressor close to the theoretical estimate.
 3. Do not select Hi-Pressure machine than requirement.
 4. Install compressors at clean, cool and ventilated room
 5. At least one machine consider of variable capacity.
 6. Design Air line for line loss less than 0.2 Bar.
 7. Consider hi-efficiency low loss dryers
 8. Use Zero loss drain valves
 9. Keep weld all the joints

Project Planning (Contd..)

- B: Humidification Plants:
 1. Optimum size of the plant (High contingency will cause of high operation cost, maint lagging, high energy consumption.)
 2. Consider all IS parameters for all equipment quantity like ,air flow rate limits on Air washer, damper, diffusers, filters, ducting, grills etc.
 3. Proper insulation on atic, false ceiling, ducting.
 4. Use energy efficient pumps for air washer.
 5. Keep provisions for seasonal changes, Like recycle of hot air for winter , Drives on pumps & fans.
 6. If possible consider auto control system to avoid operation failure at increase efficiency.
 7. Commissioning of plant with comparison of velocity, humidity, air changes and energy

Project Planning (Contd..)

■ C: Transformer:

1. Keep transformer close to load centre.
2. Select Low loss transformer
3. Select optimum rating transformer with comparison to capital cost and running losses cost . For distribution transformer 60-70% loading is economical.
4. Consider OLTC/Auto transformrs

D. Motors:

1. Consider EFF1 motors for project, diff of cost with normal eff will recover in short period

E. Metering system:

1. Consider on line measuring and monitoring system like KWH meter, Air flow meters,

F. Cablings& Capacitors:

1. Select the cable considering line losses less than 1%
2. Install capacitor in parallel with higher load

G: Lighting:

1. Consider hi-eff low watt lights
2. Consider LED lights for street lights
3. Keep stabilizer on light circuit

Compare life cycle cost of equipment/Machine before selection



OTHERS

Boiler Capacity		1.5TPH	
Make		Thermax	
Design Pressure		10.5Bar	
Working Pressure		7Bar	
Design For Fuel		Steam Coal	
Fuel using		Bhuj Lignite	
Specific Heat		3200Kcal/Kg	
Steam Application		Fibre Dying	
Boiler Efficiency(Calculated)		63%	
Fibre Dyed		80Tons/Month	
working days		15days/Month	
Steam Consumed		5Kgs/Kg fiber	
Lignite Consumed		150Tons/Month	
Feed water Temp		30 deg Cel	
Condensate Recovery		Zero	
After Installation of Steam Recovery system			
Feed water temprature		85deg Cel	
Feed Water Used/Month		400KL/Month	
Energy Saved		220Lac Kcal	
Fuel Saved		10.9Tons/Month	
Cost of Fuel		2100/Ton	
Net Saving(Rs/Mth)		0.23	Lacs
Cost of Condesate RecoverySyatem(RS)		3.2	Lacs
ROI		14	Months

Case Study of Eco-Ventilator in place of Exhaust Fans

Location: Dye house			
S.N.	Particulars		Units
1	No.of Exhuast Fans Installed	14	Nos
2	Power Consumption/Fan	0.75	KW
3	Avg Run Hrs	20	Hrs
4	Total Energy/Day	210	KWH
5	Operation Cost/Annum	330750	Rupees
6	No.of Eco-ventilators in place of Exhaust Fans	40	Nos
7	Cost of Fans	200000	Rupees
8	ROI	7	Months

Case Study of DG Set

DG Set Performance(Captive power contineous operated plant)

Particulars	Units	FRP	FRP	SS	SS	New C.T.
		2001	2002	2003	2004	2005
Charge Air Tempratures	Deg Celcius	75-81	75-81	68-73	65-70	60-65
Cooling water Temp(Inlet)	Deg Celcius	52	52	46	42	40
Cooling water Temp(Outlet)	Deg Celcius	42	42	35	32	30
Run Hrs	Annual Hrs	7819	7928	8339	8410	8561
Units Generated	MWH	29.05	29.399	30.77	32.236	32.53
Fuel Consumption	Gms/Kwh	227.13	227.11	223.02	222.11	220.65
Investments	RS in Lacs	0.00	0.00	0.50	0.00	6.00
Annual Savings	RS in Lacs		0.06	12.65	16.18	21.08

Steps Taken

- 1 Cooling system modified
 - i) Replacement of fan by Hi-Eff Fan
 - ii) Replacment of cooling tower
- 2 Charge air coolers modified

Monitoring & Measurements

For all these activities measurement and monitoring of energy parameter is very essential, Hence need continuous monitoring by suitable instruments



Thank You