

Arya Vaidya Sala, Kottakkal

Arya Vaidya Sala, Kottakkal is pioneer in the field of Ayurveda. The main activities include manufacturing Ayurvedic Medicines and is having its first unit located at Kottakkal which was started in 1902. Earlier, medicines were manufactured in the traditional way using fire wood as medium of heating for processing of medicines. Since 1968 the unit has been using Furnace Oil as fuel and steam boilers for steam generation. The major process heating is carried out in steam vessels called drug boilers and jacketed pans. Steam generated from boilers through steam header and PRS stations to 3 major steam plants. Electricity is the second utility by which machineries are working. We have mostly lower HP motors with the maximum rating being 40 HP for Pulveriser. The mostly produced items are Arishtas, Kashayas, Ghrithas (medicated ghee) Oils, tablets, Lehas, Bhasmas, Rasakriyas etc. The factory is work in 3 shifts for 360 days in a year.

Energy conservation details

As a part of our energy conservation measures, we organized training programmes for workers, staff and executives of institution. In addition we are conducting in-plant awareness regarding proper operation of equipments, switching off or lights, fans, etc. when not required, steam wastage by closing of by-pass valves, rectifying leakages in plants etc.

Energy Conservation plans & targets

1. Staggering the load to improve load factor in three shifts.
2. Incorporating VFD drive for blower motor for varying load conditions in the boilers
3. installing steam flow meter at strategic load points to monitor and control steam energy more effectively.
4. Installing a lighting circuit transformer to save electricity.
5. Giving of steam piping to reduce pressure drop to be carried out in a phased manner.
6. Water source pumps to be replaced in a phased manner by submersible pumps of lower HP

Energy conservation achievements

1. APFC Panel to improve p.f.
2. Insulated feed water tank
3. Installing Ball Float trap in place of TD Traps
4. providing insulation to condensate lines and complete recovery of condensate and transferring to boiler
5. Condensate mixing tank to utilise maximum heat efficiency
6. Installing capacitors at load centers for improving p.f to 0.98
7. Installing energy efficient tube lights.
8. replacing incandescent lights with tube lights.
9. Replacing old cooling tower with lower HP high efficiency FRP Cooling tower.
10. Replacing 10 HP motor for counter line chuck with 5 HP.

Environment and Safety

Our organisation is committed to the aspect of health and safety for all individuals. We are having effluent treatment plants for treating effluent from the factory.

We are monitoring the stack emissions regularly to keep the surroundings pollution free.

Since our effluents are having only oil contents, the water after treatment is being used for vegetable cultivation in our own fields.

- 16.5 A condensate mixing tank with flash steam utilised for heating of condensate and fresh make up water was commissioned on 30.1.2005

An investment of Rs.69000/- was made for the installations. We are getting an average temperature of 97°C for condensate water.

We are having an annual savings of 3% in Furnace Oil by higher feed water temperature as a result. An amount of Rs.1,71,065/- for 2 months in savings is observed.

Condensate Tanks


2 Nos. Condensate collection and pumping systems were installed in April 2004 near our Pilot Plant and near Sambharanam Section. Investment was Rs.30,000/-. We are having maximum condensate recovery by these two tanks with pumps back to boiler house feed water tank. A savings of 0.3% in Furnace Oil is obtained with maximum recovery of condensate.

Cooling Tower


A FRP Cooling Tower was installed in place of old wooden frame work cooling tower for the evaporator. An investment of Rs.1,10,000/- including commissioning charges was made. Apart from savings of 2 HP in electrical power, effective head transfer and operational effectiveness are found in practice. Since this was installed in March 2005, savings in power for one month only is observed. This is Rs.4455/- for the month.

APFC Panel and Capacitors at Load Centre

An APFC Panel with 100 KAVR Capacitor was installed which will automatically switch on the Capacitors to maintain p.f. above 0.96. The individual capacitor provided for higher 4 Motors improved the system p.f. further to 0.98



Furnace Oil Consumption (in Kilo Litres)



2 c. Scientific Energy consumption (SEC) Reduction during the period 2003-2005					
Year	Product	*kWh/tonne	% Reduction over 2003-04	*MkCal/Tonne	% Reduction over 2002-03
2003-04	Arishtam	0.6747	Nil	0.016761	10.13
	Kashayam	0.9165	Nil	0.012717	11.49
	Tablet	0.295	18.95	0.005513	9.56
	Ghritham Measuring	0.1043	Nil	0.017556	10.27
	Ghritham Weighing	0.1141	8.611	0.018383	18.29
	Oil Measuring	0.8703	6.93	0.013031	24.46
	Oil Weighing	0.8245	16.05	0.013027	9.73
	Leham	0.2879	0.5183	0.007595	9.873
2004-05	Arishtam	0.5258	22.06	0.01671	Nil
	Kashayam	0.8109	11.52	0.012538	2.9
	Tablet	0.272	6.7	0.005632	Nil
	Ghritham Measuring	0.8866	Nil	0.01754	0.09
	Ghritham Weighing	0.9019	Nil	0.018946	Nil
	Oil Measuring	0.7336	15.7	0.007122	45
	Oil Weighing	0.5867	28.8	0.013364	Nil
	Leham	0.2741	4.7	0.007567	0.3
Remarks if any					

2 d. Scientific Energy consumption Comparison with National & International Best Values (S No.12)			
Unit' values		*National / International Best Values	
Product	Figures for the current year (2004-05)	National	International
	Electrical	NA	
	Thermal		
Remarks if any			

3 Annual Energy Savings and Annual Sales Turnover				
Year	Annual Savings (Rs.Lakhs) (i)	Energy achieved	Annual Sales Turnover (Rs. Lakhs) (ii)	Annual Savings achieved / Annual Sales Turnover (in %) (i/ii) x 100
2002-03				
2003-04				
2004-05				

4. Specific energy consumption target as achieved during 2004-05 [Ref S.No.19(a)]						
Specific energy consumption or use actual units						
Planned Target for 2004-05 (a)		Actually achieved in 2004-05 (b)		% Reduction (+) or increase (-) $\frac{(a-b)}{a} \times 100 \%$		Money saved during 2004-05
*kWh/tonne	*Mkcal/tonne	*kWh/tonne	*Mkcal/tonne	*Electrical	Thermal	Rs. Lakhs

5 Planned specific energy consumption target for the year 2005-06 & 2006-07 [Ref S. No.19(b)]				
Year	Electrical	Thermal	Reduction over the year 2004-05	
			Electrical	Thermal
2004-05 (Base year)				
2005-06				
2006 - 07				



Asst.Gen. Manager inaugurating programme on Energy conservation conducted by Energy Management Centre.



Dharsan Unnithan of Energy Management Centre on a Session



Our Managing Trustee Dr. P.K.Warrier Inaugurating Programme on Energy conservation conducted by PCRA



Manoj of PCRA handling the Session



APFC Panel Installed at Main Switch Board



Insulated Feed Water Tank at Boiler House



Condensate Recovery Tank



Pressure Powered Pump at Kashayam Plant



Reduction of Motor
HP for the counter
line AMMIE



Full View



Energy Efficient FRP Cooling Tower



Condensate Recovery System



Capacitor Installed For 20HP Disintegrator Motor at Load Centre