

# Identification of Energy Savings Opportunity

Category	Example
<b>Thermal Utilities</b>	<b>Fuels and combustion, Boilers, Steam, Furnaces, Insulation / refractory,</b>
<b>Electrical Utilities</b>	<b>Motors, Air System, HVAC &amp; Refrigeration, Fans / Blowers, Pumps, Cooling towers, Lighting, DG set, Electrical Systems ( PF improvement, Soft Starter, VVVF etc....)</b>
<b>Reduction of energy waste</b>	<b>Idle running, Leakages, Waste heat recovery etc...</b>


# Significant Aspects for energy gain

- Optimization of pumps, blowers and compressors efficiencies
- Optimization of production process
- Increase capacity utilization
- Improvement in operation and Maintenance practices.
- Reduction in Start up and shutdown.

# Guidelines – Potential Energy Savings

- Low cost - Medium / High return
- Medium cost - Medium / High return
- High cost - High return

# Energy Conservation Activities



# Energy Savings - Hot Strip Mill



# Low Cost Projects – Hot Strip Mill

## 1. Replacement of electronic ballasts for Tube light fittings.

Replaced - 500 nos. Energy saving - 11 KW

Energy saving per Year - 0.97 Lakh kWh

Saving per year - 3.86 Lakhs @ 4.0 Rs / kwh




# Low Cost Projects – Hot Strip Mill

## 2. Replacement of conventional Indication assembly by Long life LED type assembly.

Replaced - 1000 nos, Energy saving - 8 KW

Energy saving per Year - 0.7 Lakh kWh

Saving per year - 2.8 Lakhs @ 4.0 kwh / Rs



## Stoppage of Idle running of equipments in HSM

- Stopping idle running of applications during shutdown and long stoppage.
- Power reduced from 6 MW to 4.4 MW

Power Saving :- 1600 KW per hour

Total :- 450 Hrs per Annum

Total Power Saving :- 7.2 Lakh kWh considering shutdowns and down time

Annual Saving :- 28.8 Lakhs @ 4.0 kWh / Rs

## Product mix and Production

- Power Saving due to product mix and proper schedule of process have increased in production rate and hence decreased in power consumption.

- Production data

2005-06 - 2546680 T at specific power – 95.84 kWh/T

2006-07 - 2919009 T at specific power – 87.54 kWh/T

Power Saving = 8.3 kWh/T at 3.72 Lakh production

Total Energy Saving :- 30.91 Lakh kWh

Annual Saving :- Rs. 123.65 Lakhs @ 4.0 kWh / Rs

# Energy Saving Summary - HSM

Description	Energy Saved – Lakh kWh	Investment Incurred - Lakhs	Savings - Lakhs
Electronic Ballast replacement	0.97	1.0	3.86
Installation of LED Lamps	0.70	-----	2.80
Stoppage of Idle equipments	7.20	-----	28.80
Process Optimization	30.91	-----	123.65
<b>TOTAL SAVINGS</b>	<b>39.78</b>	<b>1.00</b>	<b>159.11</b>

# Energy Savings - Utility



# Low Cost Projects - Utility

## ☀ Centrifugal Chillers ( Capacity 300 TR – 04 nos ) :

Evaporator and condenser's tube side ( water ) as well as shell side ( refrigerant ) were Chemically cleaned resulted in better heat transfer and enhancing the individual capacity. Stopping of one chiller. Refrigerant side first time done. Energy Saving 143 KW

Investment : Rs. 1.11 Lakhs.

Total energy savings : 12.8 Lakhs kWh

Savings = 51.2 Lakhs per annum @ 4.0 Rs/kWh



**Annual Savings (2006-07)**  
**RS. 51.2 Lakhs**

# Low Cost Projects - Utility

**Compressor Cooling Pump** : One running pump stopped after establishing the flow with two pumps. **Energy savings : 90kW**

Total Energy savings : 7.88 Lakhs kWh

Cost Saving : 31.54 Lakhs per annum @ 4.0 Rs/kWh.

**Chilled Water Pump** : One running Pump stopped after establishing the flow with two pumps and Chemical cleaning of Evaporators. **Energy savings : 50kW**

Investment :- Rs. 0.21 Lakh

Total Energy savings : 4.38 Lakhs kWh

Cost Saving : 17.52 Lakhs per annum @ 4.0 Rs/kWh.



**Annual Savings (2006-07)  
RS. 49.06 Lakhs**

# Low Cost Projects - Utility

## Condenser Cooling Water Pump :

One running pumps stopped after establishing the flow with two pumps and chemical cleaning of Condensers. This pump will required to be run in summer due to High Water temp. ( Saving for 250 days per annum only ).

Energy Saved : 60 W

Total energy savings : 3.6 Lakhs kWh

Cost Savings : Rs. 14.4 Lakhs per annum @ 4.0 Rs/kWh



**Annual Savings (2006-07)**  
**RS. 14.4 Lakhs**

# Low Cost Projects - Utility

**Oxygen Plant Centrifugal Chiller** : Chilled water flow & Secondary water flow established in Pre column chamber for minimize the loss of chilled water. Energy savings : 47.5kW

Total Energy Savings – 4.16 Lakh kWh

Cost Savings - 16.65 Lakhs @ 4.0 Rs/kWh

**Roll Coolant Pump, CRM** : Flow adjustments done by regulating the valves after optimization. Energy savings : 54kW

Total Energy Savings – 4.73 Lakh kWh

Cost Savings - 18.93 Lakhs @ 4.0 Rs/kWh

**Annual Savings (2006-07)  
RS. 35.58 Lakhs**

# Medium Cost Projects - Utility

## Plate type Heat exchangers, EAF cooling water system :

Chemical cleaning carried out resulted in improvement in efficiency of supply water pumps.

Total Investment :- Rs. 9.5 Lakh

Energy Savings :- 47.62 Lakhs kWh per annum

Cost savings : 190.48 Lakhs per annum @ 4.0 Rs/kWh



**Annual Savings (2006-07)**  
**RS. 190.48 Lakhs**

# Medium Cost Projects - Utility

**Chiller # 4** : Enhanced the capacity ( by 9 TR ) by increasing the condenser water flow from 47 to 85 m<sup>3</sup>/hr after installing the booster pump, Model : KDS 1537+ , Kirloskar.  
 Energy Savings - 28.2 kW

Total Investment :- 0.28 Lakh

- ✦ Total energy savings : 2.47 Lakh kWh
- ✦ Cost Savings 9.90 Lakhs per annum @ 4.0 Rs/kWh

**Annual Savings (2006-07)**  
**RS. 9.90 Lakhs**

# Medium Cost Projects - Utility

**Crane 160 # 2 Cabin A/C** : Old ductable unit modified in split one. Energy Saving :- 3.45 kWh

**Investment : Rs. 0.85 Lakh**

- ✦ Total energy savings : 0.3 Lakhs kWh
- ✦ Cost Savings 1.21 Lakhs per annum @ 4.0 Rs/kWh

**Annual Savings (2006-07)  
RS. 1.21 Lakhs**

# High Cost Projects - Utility

## ☀ EAF 1 & 2 Cooling system :

- ☀ 02 nos Plate type heat exchangers added. This resulted in truncation of peak temp. helping SMP to achieve a new milestone. Additionally, 01 no pump of EAF Primary system stopped.

Investment :- Rs. 80 Lakhs

- ☀ Total Energy Savings :- 45.72 Lakhs kWh
- ☀ Cost Savings :- 182.88 Lakhs @ 4.0 Rs/kWh

**Annual Savings (2006-07)**  
**RS. 182.88 Lakhs**

# High Cost Projects - Utility


## Resource Saving :

- ★ Wooden Drift Eliminators replaced with PVC " C " Type Drift Eliminators in EAF Secondary cooling towers. This resulted in reduction of Specific Water consumption of EAF by  $0.02 \text{ m}^3/\text{Tonne}$  of liquid steel.
- ★ Total Saving of Water consumption :-  $60000 \text{ m}^3$
- ★ Water treatment, pumping etc.. cost is  $14 \text{ Rs}/\text{m}^3$
- ★ Energy Saving :-  $2.1 \text{ Lakh kWh}$
- ★ Cost Saving :-  $\text{Rs. } 8.4 \text{ Lakh per Annum}$



# Energy Saving Summary - Utility

Description	Energy Saving – Lakh kWh	Investment Incurred Lakhs	Savings - Lakhs
Stopping of one chiller	12.80	1.11	51.20
Stopping of cooling pump	7.88	----	31.54
Chilled water pump stopped	4.38	0.21	17.52
Condenser water pump stopped	3.60	----	14.40
Chilled water flow optimization	8.89	----	35.58
Efficiency improvement	47.62	9.5	190.48
Booster pump installation	2.47	0.28	9.90
AC duct modification	0.30	0.85	1.21
Heat Exchanger installed	45.72	80.00	182.88
Resource saving	2.10	----	8.40
<b>TOTAL</b>	<b>135.76</b>	<b>93.91</b>	<b>543.04</b>

# Energy Savings - SMP



## Increase in Hot DRI



Increase in the usage of Hot DRI in Steel Making.

[A project being pursued hand in hand with HBI and HED]

Total Energy Saving = 26007900 kWh

Increase in Annual Savings (2006-07)  
RS. 1040 Lakhs

## Energy saving By Installing CFL

- **Replacement of Conventional 160w lamp with 23w CFL (40 nos.)**

Energy saving	: 40505 kWh
Saving	: Rs. 1,92,019/- Year
Investment on	: Rs. 8520/-
Payback Period	: 16 days

Annual Savings (2006-07)  
RS. 1.92 Lakhs

Replacement of conventional Indication assembly by Long life LED type assembly.

Replaced - 718 nos, Energy saving - 1.149KW

Energy saving per Year - 10063 kWh

Saving per year - Rs. 40,253/- @ 4.0 kwh / Rs



# Energy Saving Summary - SMP

<b>Description</b>	<b>Total Energy- Lakh kWh</b>	<b>Investment Incurred - Lakhs</b>	<b>Savings - Lakhs</b>
HDRI	<b>260.08</b>	<b>100</b>	<b>1040</b>
CFL Installation	<b>0.41</b>	<b>0.08</b>	<b>1.92</b>
LED lamp indication	<b>0.10</b>	<b>----</b>	<b>0.40</b>
<b>TOTAL</b>	<b>260.59</b>	<b>100.08</b>	<b>1042.32</b>

## LONG CONVEYOR XF 1.14 SINGLE DRIVE OPERATION

- Long conveyor XF 1.14 is approx. 1KM in length having two 250KW LT Squirrel cage induction Motors, one at head end & other at tail end. Both the Motors are running with 250KW AC VVVF drive Siemens make.
- Drives are connected to Siemens PLC through Profibus communication
- Conveyor design capacity is 2000TPH
- Motors full rated current is 420A.
- Current drawn by two Motors when running with 60% speed i.e. 900 RPM is approx 100-150A (each motor) at normal flowrate 800TPH

# Energy Saving - MH

## Calculation :-

- Power saving is approx 27.8 % ( $77/256*100$ )
- Power Saving per Hour is approx **31.2KW**  
 Current reduced by running with one drive =  $276-199 = 77A$   
 KW Saving = (  $1.732 \times 260V \times 77A \times 0.9PF$  )  
 (Average current drawn is 199A)
- Monthly power saving is approx **16,474 KWH** (Considering 22 days operation)
- Energy Savings :- 1.98 Lakhs kWh per annum
- Cost Saving :- **7.91 Lakhs per annum @ 4.0 Rs/kWh**

Total Annual Savings Rs. 7.91 Lakhs

## Replacement of Quench Tank Pumps

- Replacement of over capacity pumps of quench tank pumps thereby reducing specific power consumption @ 0.2 kWh/t.

**Total Production: 3590302 MT**

**Total energy saving  $3590302 \times 0.2 = 7.18060$  Lakh kWh.**

**Cost Saving = Rs. 28.72240 Lakhs @ Rs. 4 / kWh**



**Total Savings Rs. 28.72 Lakhs**

## Replacement of compressor

- At Mod 2, existing seal gas compressor replaced with water ring compressor, thereby reducing specific power consumption.
- **Plant running hours: 8063 hrs**
- Earlier capacity of seal gas compressor motor 700 kW, Compressor replaced with water ring compressor motor capacity 380kW.
- Energy Saving per Hour – 160kw.
- Total Running hours of the compressor – 8063 hrs.
- **Total energy saving –  $8063 \times 160 = 12.90$  Lakh kWh**
- **Cost Saving = Rs. 51.6 Lakhs @ Rs 4 / kWh**



Total Savings Rs. 51.60 Lakhs

## Reduction in NG consumption

- At all modules reduction in oxygen consumption and zero Flaring operation, to reduce NG specific consumption @8 SM3/t.
- Total Production: 3590302 MT
- NG saved :-  $3590302 * 8 = 31922416$  sm3
- Cost Saving :- Rs. 255.3423 Lakhs



Total Savings Rs. 255.34 Lakhs

# Energy Saving Summary – MH / HBI

<b>Description</b>	<b>Total Energy Saved - Lakh kWh</b>	<b>Investment Incurred - Lakhs</b>	<b>Savings - Lakhs</b>
<b>Conveyor motor stopped</b>	<b>1.98</b>	<b>-----</b>	<b>7.91</b>
<b>Replacement of Quench Tank Pumps</b>	<b>7.18</b>		<b>28.72</b>
<b>Compressor Replacement</b>	<b>12.90</b>		<b>51.6</b>
<b>TOTAL Savings</b>	<b>22.06</b>		<b>88.23</b>

## Reduction in Lighting Transformer Voltage

- **Problem** : At 440 voltage, single phase voltage was 255 V. Total power consumption was 476.1 KW
- **Analysis** : Voltage reduced to 400 V by changing the tap position to make single phase voltage 230 V. Total Power consumption measured is 387.32 KW.
- **Result** : Energy Saving **476.10 - 387.32 = 88.78 KW**  
Energy of 2130.72 KWH every day.
- **Energy Saved** : **7,77,712** KWH per annum
- **Cost Saved** : **Rs. 3110848** at @ 4.0 kWh / Rs

Annual Savings (2006-07)  
RS. 31.11 Lacs

## VVVF Drive Installation

- **Description:** VVVF drive installation for rapid cool Motor
- **Analysis :** VVVF drive installed for rapid cool motor and reduced 5 Hrs cycle time for Base Fan motor(37 KW), Rapid cool Motor(11 KW) and Cooling hood motor(22 KW). Power Saving of 8.85, 6 and 7.75 KWH respectively.
- **Result :** Energy Saving **113 KW**
- **Investment :- 1.2 Lakhs**
- **Energy Saved : 2,90,322 KWH per annum**
- **Cost Saved : Rs. 11,61,328 @ 4.0 kWh / Rs**

Annual Savings (2006-07)  
RS. 11.61 Lacs

## Speed reduction of base fan motor

- **Description:** Speed reduced from 1450 RPM to 1000 RPM at the time of N2 purging
- **Analysis :** Output power at Speed at 1450 RPM=37 KW  
power at Speed at 1000 RPM=15 KW
- **Result :** Energy Saving **22 KW per 4 Hrs cycle**
- **Energy Saved :** **2,26,500 kWh** per annum
- **Cost Saved :** **Rs. 9,06,000 @ 4.0 kWh / Rs**

Annual Savings (2006-07)  
RS. 9.06 Lacs

## Energy saving By Installing VVVF Drive

- ☀ **VARIABLE FREQUENCY DRIVE INSTALLED AT ARP (CRM COMPLEX) FOR 02 NOS OF BLOWERS.**



# Medium Cost Projects – ARP (CRM)

## Energy saving By Installing VVVF Drive

- Conversion of 315 KW HT Motor by 250KW LT Motor. With Variable frequency drive.
- Installation of Variable frequency drive for V30 Blower

**Saving : Rs. 18,00,000/- Year**

**Investment on VFD : Rs. 12,00,000/-**

**ROI : 8 MONTHS**



Annual Savings (2006-07)  
RS. 18 Lakhs

# Analysis Of Data



## ANALYSIS OF ENERGY SAVINGS AFTER INSTALLATION OF VVVF DRIVE

SR NO.	REGENERATED ACID PRODUCTION (KL)	V-31MOTOR			V-30 MOTOR		
		EXISTING HT MOTOR METER READING (KWHr)	AFTER INSTALLATION OF VVVF DRIVE (KWHr)	DIFFERENCE (KWHr)	EXISTING METER READING OF V30 BLOWER (KWHr)	AFTER INSTALLATION OF VVVF DRIVE (KWHr)	DIFFERENCE (KWHr)
1	98	5500	4023	1477	2380	1973	407
2	98	5100	4459	641	2320	2250	70
3	96	5200	4310	890	2500	2210	290
4	97	5400	4027	1373	2400	2236	164
5	86	5300	3570	1730	2277	2040	237
		Average		1222.2	Average		233.6

APPROX. 1500 KWhr Power Saving per day

Plant Running per year : 300 days

Total Power Savings :  $1500 \times 300 = 450000$

Total Saving per year :  $450000 \times 4 = 1800000$  (Eighteen Lacs per year)

Total Investment : 1200000/- (Twelve Lacs Rupees)

ROI : 8 Months

## Optimization of Effluent Discharge in PKL1

- Effluent Discharge Reduced from 9.00 KL/hr to 4.00 KL/hr

Power Saving :- 2.2 KW /hr

Total Power Saving :- 14256 kWh considering (540 hrs Running per month. )

Annual Saving :- 57,024/-

## Optimization of Effluent Discharge in PKL2

- Effluent Discharge Reduced from 11.0 KL/hr to 7.5 KL/hr

Power Saving :- 3.75 KW /hr

Total Power Saving :- 24300 kWh considering (540 hrs Running per month. )

Annual Saving :- 97,200/-

# Energy Saving Summary – CRM/DSC

Description	Energy Saving – Lakh kWh	Investment Incurred Lakhs	Savings - Lakhs
Reduction in Lighting voltage	7.78	--	31.11
VVVF Drive Installation at BAF	2.90	1.20	11.61
Speed reduction at BAF	2.27	--	9.06
VVVF Drive at CRM	4.50	12.00	18.00
Optimization of Effluent Discharge at PKL	0.39	--	1.55
<b>TOTAL</b>	<b>17.84</b>	<b>13.20</b>	<b>71.33</b>

# Total Saving Summary – Essar Steel



<b>PLANT</b>	<b>Energy Saved - Lakh kWh</b>	<b>Investment Incurred - Lakhs</b>	<b>Savings - Lakhs</b>
<b>HOT STRIP MILL (HSM)</b>	<b>39.78</b>	<b>1.00</b>	<b>159.11</b>
<b>UTILITY</b>	<b>135.76</b>	<b>93.91</b>	<b>543.04</b>
<b>STEEL MELT SHOP (SMP)</b>	<b>260.59</b>	<b>100.08</b>	<b>1042.32</b>
<b>HBI and MH</b>	<b>22.06</b>	<b>----</b>	<b>88.23</b>
<b>CRM / DSC</b>	<b>17.84</b>	<b>13.20</b>	<b>71.33</b>
<b>TOTAL</b>	<b>476.03</b>	<b>208.19</b>	<b>1904.03</b>

- **Proposed projects at HSM :**

- Optimization of air usages during various mill application.

- Primary audit is done with the help of external agency.

- Feasibility report is under progress.

- **Replacement of 160 W HPMV lamp by 70 W HPSV lamp.**

- Feasibility report is made.

- Phase wise implementation, 200 this year.

- Expected savings, 5 Lakhs per annum.

- Proposed projects at HSM :
  - **Revamping of Reheating furnace.**
    - ❑ Proposal is received from external agency.
    - ❑ Feasibility study is under progress.
  
  - **Installation of Energy Management system.**
    - ❑ SKADA system is procured.
    - ❑ Will be Commissioned by DEC – 2007.
    - ❑ Expected results are :
      - Real time data for better monitoring and analysis.

## Future projects at Essar Steel

### 1. Oxy-Fuel Project – HSM

Total Cost –Rs 5.00 crores

Activities under process.

Benefits- More productivity benefits expected. Nitrogen dioxide emissions may possibly reduce.

## Future projects at Essar Steel

### 2. Utilization of Waste heat gases from Electric Arc furnaces.

- Preliminary evaluation has been carried out by Thermal Systems – Hyderabad. Party has carried out projects of such nature involving dust in Birla Copper (Hindalco) and Hindustan Zinc .  
The technical report from Thermal systems is expected.
- Possibility of power generation is up to 50 MW. With installation of single turbine system/hunting turbine system  
Cost of project is up to 4.5 crore per MW. Total up to 225 crores.
- An preliminary estimate of Carbon credits at will be 4000 CER/MW that is up to 200,000 CER/year using thumb rules.

## Future projects at Essar Steel

### 3. 25 MW waste heat recovery project

Government of India - approval received on 20th April 2007.  
We are implementing 19 MW project – With basis of 4000 CER/MW total carbon credits is up to 76000 CER/annum.

Cost of project is 75 crores.

Equipment such as Chinese Boilers, Siemens Electrical, has been ordered . Tata Consulting Engineers is project consultant for same.