


Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Blinding of one stage in the feed pump to optimize the flow & pressure				Thermal Power Stations	
Year to be filled by BEE					Technology: Optimization	
<p><u>Description of the energy conservation measure:</u> In our 600 MW Thermal Power Plant (6x50MW +3x100MWUnit) the feed pump is a major energy consumer (Motor output-2000KW). The Feed Pumps are 10 Stage pumps and the Pump parameters are: Flow – 270 M³/Hr, Pressure-158Kg/Sq.met. Our requirement at 100 % MCR of the unit is nearly Flow-220 M³/Hr, Pressure-145Kg/Sq.met. Hence in consultation with Original Equipment Manufacturer, it is decided to blind the 6th Stage to optimize the flow and pressure to 225 M³/hr and 147 Kg/Sq.met respectively and the same is carried out in one feed pump. The power consumed before modification at 48 MW Unit load is 1363 kW and the power consumed after modification at 48 MW Unit load is 1207 kW.</p>						
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification			
XXXXX			XXXXX			
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli						
Total investment: Rs. 0.1 Lakhs			Aug -2006			
First year energy cost savings, Rs.: Rs. 17.21 Lakhs						
First year other savings, Rs.:						
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other	
Energy consumption before	8,596,714					
Energy consumption after	7,612,790					
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	1.7487 /kWh**			** selling prize Rs.1.7487/kWh		
Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773				We authorise Bureau to use this information for dissemination -sd- General Manager, Thermal Power Station-I Date:30.10.2007		
Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com						

Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Replacement of conventional tube light with energy efficient tube lights			Thermal Power Stations	
Year to be filled by BEE				Technology:	
Description of the energy conservation measure: 190 Nos. of conventional tube lights are replaced by Energy Efficient tube lights (Asian E+). The Power consumption of Conventional tube light is 54 Watts, whereas the power consumption of energy efficient tube light is 28 Watts. The Power saving per tube light is 25 Watts (average).					
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification		
XXXXXX					
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli					
Total investment: Rs. 1.32 Lakhs			Aug -2006		
First year energy cost savings, Rs.: Rs. 0.36 Lakhs					
First year other savings, Rs.:					
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other
Energy consumption before	44939				
Energy consumption after	24134				
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	1.7487 /kWh**			** selling prize Rs.1.7487/kWh	
Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773 Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com				We authorise Bureau to use this information for dissemination -sd- General Manager, Thermal Power Station-I Date:30.10.2007	

Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Replacement of damaged Insulation		Thermal Power Stations		
Year to be filled by BEE			Technology: O&M Practices		
<p><u>Description of the energy conservation measure:</u> Insulation audit was conducted and it was found that the heat losses occurred at main steam line, Emergency Stop Valve, High Pressure Heaters and turbine side Valves due to Insulation damage. The damaged insulation were removed and re-insulated during Annual Maintenance.</p>					
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification		
XXXXX			XXXXX		
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli					
Total investment: Rs. 12.0 Lakhs			2006-07		
First year energy cost savings, Rs.: Rs. 186 Lakhs					
First year other savings, Rs.:					
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other
Energy consumption before					Total fuel saved 27424 Tonnes.
Energy consumption after					
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	Rs. 678 /Tonne				
<p>Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773 Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com</p>				<p>We authorise Bureau to use this information for dissemination</p> <p style="text-align: center;">-sd- General Manager, Thermal Power Station-I Date:30.10.2007</p>	

Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Reduction of Excess Air			Thermal Power Stations	
Year to be filled by BEE				Technology: O&M Practices	
<p><u>Description of the energy conservation measure:</u> Oxygen in Flue gas is the indication of excess air. Normally for lignite the Oxygen % in the flue gas shall be 5 to 5.5 % in the case of optimum excess air quantity in our boiler. In the energy audit it was found that the oxygen quantity in the flue gas was around 6.2 %. The operation air regime is adjusted such that the oxygen quantity in the flue gas is only 5.5 %.</p>					
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification		
XXXXX			XXXXX		
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli					
Total investment: Rs. 0.0Lakhs			2006-07		
First year energy cost savings, Rs.: Rs. 13.1 Lakhs					
First year other savings, Rs.:					
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other
Energy consumption before					Total fuel saved 1932Tonnes.
Energy consumption after					
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	Rs. 678 /Tonne				
Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773 Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com				We authorise Bureau to use this information for dissemination <p style="text-align: center;">-sd- General Manager, Thermal Power Station-I Date:30.10.2007</p>	

Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Reducing the flue gas loss			Thermal Power Stations	
Year to be filled by BEE				Technology: O&M Practices	
<p><u>Description of the energy conservation measure:</u> The flue gas temperature at the exit is an indication of heat transfer in the furnace. In the energy audit it was found that the flue gas temperature at exit level was 176 Deg.C. By increasing the frequency of soot blowing, the heat transfer in the water wall is increased and the flue gas temperature is reduced from 176 to 170 Deg.C.</p>					
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification		
XXXXX			XXXXX		
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli					
Total investment: Rs. 0.0Lakhs			2006-07		
First year energy cost savings, Rs.: Rs. 12.61 Lakhs					
First year other savings, Rs.:					
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other
Energy consumption before					Total fuel saved 1860Tonnes.
Energy consumption after					
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	Rs. 678 /Tonne				
Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773 Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com				We authorise Bureau to use this information for dissemination <div style="text-align: center;">-sd- General Manager, Thermal Power Station-I Date:30.10.2007</div>	

Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Reducing air ingress in Boiler			Thermal Power Stations	
Year to be filled by BEE				Technology: O&M Practices	
<p><u>Description of the energy conservation measure:</u> The air ingress in boiler increase the quantity of air handled by the ID fan which in turn rise the power consumption of the ID fan. In the energy audit it was found that the air ingress in a boiler is 46 % and the quantity of air leakage that can be reduced is estimated as 31%. The measures were taken to attend the air leakage during AM.</p>					
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification		
XXXXX			XXXXX		
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli					
Total investment: Rs. 10.0Lakhs			2006-07		
First year energy cost savings, Rs.: Rs. 26.23 Lakhs					
First year other savings, Rs.:					
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other
Energy consumption before					Total energy saving is 15lakhs units
Energy consumption after					
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	Rs. 1.7487/ KWHr				
Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773 Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com				We authorise Bureau to use this information for dissemination <p style="text-align: center;">-sd- General Manager, Thermal Power Station-I Date:30.10.2007</p>	

Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Replacement of old Air Handling Unit			Thermal Power Stations	
Year to be filled by BEE				Technology: O&M Practices	
<p><u>Description of the energy conservation measure:</u> Heat transfer in 2 Air Handling Units were poor due to damage of fins for which airflow was restricted. The Air Handling Units are replaced with new Air Handling Units.</p>					
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification		
XXXXX			XXXXX		
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli					
Total investment: Rs. 5.0Lakhs			2006-07		
First year energy cost savings, Rs.: Rs. 6.68 Lakhs					
First year other savings, Rs.:					
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other
Energy consumption before					Total energy saving is 3.82lakhs units
Energy consumption after					
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	Rs. 1.7487/ KWHr				
Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773 Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com				We authorise Bureau to use this information for dissemination <p style="text-align: center;">-sd- General Manager, Thermal Power Station-I Date:30.10.2007</p>	

Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Passing in the re-circulation valve of Main condensate pump				Thermal Power Stations	
Year to be filled by BEE					Technology: O&M Practices	
<p><u>Description of the energy conservation measure:</u> The power consumption of Main condensate pump in unit-2 (50 MW) our Thermal Power Station was found more during normal operation. This increase in power consumption was due to passing in the re-circulation valve. It was attended.</p>						
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification			
XXXXX			XXXXX			
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli						
Total investment: Rs. 0.0Lakhs			2006-07			
First year energy cost savings, Rs.: Rs. 1.8 Lakhs						
First year other savings, Rs.:						
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other	
Energy consumption before	891634					
Energy consumption after	788753					
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	Rs. 1.7487/ KWHr					
Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773				We authorise Bureau to use this information for dissemination <div style="text-align: center;">-sd- General Manager, Thermal Power Station-I Date:30.10.2007</div>		
Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com						

Energy Conservation Measure implemented in 2006-2007

ID to be filled by BEE	Reduce Idle running hours in conveyor system				Thermal Power Stations	
Year to be filled by BEE					Technology: O&M Practices	
<p><u>Description of the energy conservation measure:</u> In the energy audit it was found that there was 4 to 5 hours idle running of conveyors in the external lignite transfer system. The Idle running hours is reduced by 2 Hours by proper co-ordination with mine personnel.</p>						
Picture/ sketch/ drawing before modification (if available)			Picture/ sketch/ drawing after modification			
XXXXX			XXXXX			
Agency that executed the project (with complete address and email): Neyveli Lignite Corporation Limited, Neyveli						
Total investment: Rs. 0.0Lakhs			2006-07			
First year energy cost savings, Rs.: Rs. 3.64 Lakhs						
First year other savings, Rs.:						
On annual basis	kWh 000'	Coal (Tons)	Gas Nm ³	Oil (kL)	Other	
Energy consumption before due to 2 hours idle running	208050					
Energy consumption after	0					
Energy tariff, Rs/ kWh/ Ton/ Nm ³ / kL ...	Rs. 1.7487/ KWHr					
Company complete address: 600 MW THERMAL POWER STATION -I, NEYVELI LIGNITE CORPORATION LIMITED, NEYVELI, CUDDALORE DISTRICT, TAMIL NADU, PIN CODE - 607 807 TeleFax:04142 -254773 Contact person who could be contacted for more information: K.BALASUBRAMANIYAN, CERTIFIED ENERGY AUDITOR / MANAGER (Regn.No.EA-2879) e-mail: enr.mgr.tps1@nlcindia.com				We authorise Bureau to use this information for dissemination <div style="text-align: center;">-sd- General Manager, Thermal Power Station-I Date:30.10.2007</div>		